



District Level Water Analysis Laboratory UP Jal Nigam (Rural), Bulandshahr

TEST REPORT

UTR NO:	: T 9249	Issue Date	09/03/2026
Sample receipt Date:	: 05/03/2026	Expired Date	09/09/2026
Customer/Party Name	: OLYMPIAN PUBLIC SCHOOL		
Address	: MUMREJPUR, DIBAI, BULANDSHAHR		
Contact No.	: 9758901700		
Date of Sampling	: 06/03/2026	Sample Code:	B 166
Sample Description	: 06/03/2026	Quantity of Sample	1000ML
Quantity	: 1	Water Source	SAMAR SEVAL WATER
Packing details	:	Sampling Method	As per IS 17614:Part-2021
Analysis Start	: 07/03/2026	Analysis Completion Date	07/03/2026
Temperature	: 26.5°C	Humidity	52%

Water Sample Provided BySatendra Kumar Sharma

Availability of Equipments:		Availability of reference standards:		Adequacy of sample quantity	01
Availability of Test method:	IS 3025	Availability of Trained person:		Duration of testing/Time of Report release	12:30 pm

TEST PARAMETER

S. N.	Test Parameters	Method	Specification		Result	(Unit)
1	pH	IS 3025 (Part 11):2017	6.5-8.5	No Relaxation	7.361	-
2	Turbidity	IS 3025 (Part 10):2017	1.0	5.00	2.955	(NTU)*
3	TDS	IS 3025 (Part 16):2017	500	2000	318.7	(Mg/L)*
4	Chloride	IS 3025(Part 32): 2019	250	1000	152	(Mg/L)*
5	Total Alkalinity	IS 3025 (Part 23):1986	200	600	200	(Mg/L)*
6	Total Hardness	IS 3025 (Part 21):2019	200	600	332	(Mg/L)*
7	Colour	APHA 23 rd Edition	5	15	13	Hazen
8	Taste	IS 3025 (Part 8) : 2017	Agreeable	Qualitative	Agreeable	Qualitative
9	Odour	IS 3025 (Part): 2018	Agreeable	Agreeable	Agreeable	Agreeable
10	Calcium as Ca	-	75	200	120	(Mg/L)
11	Magnesium as	-	30	100	92.38	(Mg/L)
Remark	"The Information regarding sample collected, submitted and Customer basic details provided by the customer itself."					

Reviewed By

Pass (✓)

Fail ()

End of Report

Manager

Olympian Public School
Mumrejpur [Debai] Bulandshahr

